

Attestation

BREEAM International

On 20 November 2020, Eurofins Product Testing A/S received a sample of coating with the product name:

PROLATEX

supplied by

Farby KABE Polska Sp. z o.o.

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the testing standards specified in Indoor Air Comfort GOLD version 6.0: EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 and ISO 11890-2, respectively (See test report no. 392-2020-00529901_B_EN and no. 392-2020-00529902_XG_EN).

- **Evaluation of the emission and content test results according to the basic level emission criteria (table 17) and VOC content criteria (table 19, Interior paint) of: BREEAM Int.: Hea 02 Indoor air quality:**

-
- Carcinogenic substances were not detectable after 28 days ($< 0.001 \text{ mg/m}^3$).
 - The sum of VOC ("TVOC") after 28 days was below the limit of 1 mg/m^3 .
 - Formaldehyde after 28 days was below the limit of 0.06 mg/m^3 .
 - VOC content of less than 30 g/L .

The tested product complies with the requirements of BREEAM International: New Construction 2016, Technical Manual: Hea 02 Indoor air quality (version SD233 issue 2.0 of July 2017).

9 February 2021



Rasmus Verdier
Analytical Service Manager



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry